

**ADVERTISEMENT FOR BIDS**

Subject to conditions prescribed by the University of California, Irvine, sealed bids for a Lump-Sum Contract are invited for the following project:

**SMALL CAP 16/17 PERIMETER SECURITY CAMERA, RESEARCH FACILITY**  
**PROJECT NO.: 5110351 CONTRACT NO.: 9943650**

**ESTIMATED CONSTRUCTION COST:** \$280,000.00  
**LICENSE CLASS REQUIRED:** C7  
**PROJECT DURATION:** ONE-HUNDRED TWENTY (120) CALENDAR DAYS  
**GENERAL DESCRIPTION OF WORK:**

The University is seeking C7 licensed security system contractors who are familiar with "Genetic" system manufacturer certification to participate in the bidding of the "Perimeter security camera at Research Facility" project which installs the perimeter security camera at (7) different academic buildings located on the University of California Irvine campus. Project scope includes but not limited to security camera (interior and exterior cameras) installation, view setting, programming and maintenance of the system.

For more project information please see our BID BOARD at [www.fm.uci.edu](http://www.fm.uci.edu)

**PROCEDURES:** Bidders may obtain bid documents beginning on **Wednesday, July 19, 2017 at 3:00 p.m.**, at **C2 Imaging**, 3180 Pullman Street, Costa Mesa, CA 92626. Contact: Andres Valle, Planwell Manager at [planwell@c2-imaging.com](mailto:planwell@c2-imaging.com) or (866) 522-8475. Bid documents will be available Monday through Friday, 7:00 A.M. to 7:00 P.M. **Option 1:** View from C2 Imaging' Planwell site by following these directions: Access the site by going to Internet Explorer to connect to [https://order.planwell.com/PWELL\\_Main.asp?mem=1027](https://order.planwell.com/PWELL_Main.asp?mem=1027) Click on Public Planroom, then search in the Find Field by "UCI Facilities, then select, Project Name and Project Number. **Option 2:** Purchase CD (Compact Disc). **Option 3:** Download file paper or bid documents either by emailing or calling C2 Imaging.

**BIDDER QUALIFICATIONS:** The successful Contractor will be required to have the following California contractor's license (s): active at the time of submission of the Bid:

**LOW VOLTAGE SYSTEMS CONTRACTOR "C7"**

The Contractor shall provide a minimum of 3 references for projects comparable in scope and size to this Project which your firm successfully completed in the State of California during the past 3 years. If you were a Subcontractor, your portion of the work must satisfy this project's qualifications. The University will conduct extensive reference checks; any bidder who does not meet all the requirements in the specifications will be eliminated.

**MANDATORY PRE-BID CONFERENCE:** The Pre-Bid Conference and Job Walk will be conducted on **Thursday, July 20, 2017 at 11:00 AM** at the UCI Facilities Management, Conference Room 122, 19172 Jamboree Road, Irvine, CA 92697-5444. Contractors arriving after **11:00 AM** will not be eligible to participate in the bid process as a General Contractor. Only bidders who participate in both the pre-bid conference and the job walk in their entirety will be allowed to bid on the Project as General Contractors. For directions consult the following link: <http://www.fm.uci.edu/directions.html>.

**BID SUBMITTAL REQUIREMENTS:** Sealed Bids shall be submitted to UCI, Facilities Management, Contract Services Office, Room 144 by **2:00 PM on Thursday, August 3, 2017.**

The successful Contractor and its Subcontractors shall be required to follow the nondiscrimination requirements set for in the Bidding Documents and to pay prevailing wage rates at location of work.

Every effort will be made to ensure that all persons have equal access to contracts and other business opportunities with the University within the limits imposed by law or University policy. Each Bidder may be required to show evidence of its equal employment opportunity policy. The successful Bidder and its subcontractors will be required to follow the nondiscrimination requirements set forth in the Bidding Documents and to pay prevailing wage at the location of the work.

The work described in the contract is a public work subject to section 1771 of the California Labor Code. For further information contact **Shaquenta Gaines**, Contracts Administrator at **(949) 824-7304**.

No contractor or subcontractor may be listed on a Bid for this project (submitted on or after March 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code section 1771.1(a)].

No contractor or subcontractor may be awarded any portion of this project (awarded on or after April 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5.

This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations.

The successful Bidder shall pay all person providing services and/or any labor on site, including any University location, no less than the UC Fair Wage (defined as \$13 per hour as of 10/1/15, \$14 per hour as of 10/1/16, and \$15 per hour as of 10/1/17) and shall comply with all applicable federal, state and local working condition requirements.

Smoking will not be permitted on UC Irvine premises; including its outdoor areas as of January 1, 2014. For more information please refer to: [chancellor.uci.edu/smoke-free/](http://chancellor.uci.edu/smoke-free/)

**ADDENDUM NO. 1**  
TO THE CONSTRUCTION DOCUMENTS  
**SC 16/17 PERIMETER SEC. CAMERA @ RESEARCH FA.**  
**PROJECT NO.: 5110351 CONTRACT NO.: 9943650**  
UNIVERSITY OF CALIFORNIA  
IRVINE CAMPUS  
July 27, 2017

**I. GENERAL**

The following changes, additions, or deletions shall be made to the following documents as indicated. All other conditions shall remain the same.

**II. QUESTIONS AND ANSWERS:**

<b>ITEM #</b>	<b>DESCRIPTION</b>
<b>Q1</b>	Data cable: Will Leviton or Superior Essex be allowed alongside Molex?
<b>A1</b>	Yes, Leviton and Superior Essex are acceptable, as long as they are equal in performance. Please refer to 27 1000, 2.01, Superior Essex is listed as an acceptable product. Follow procedures in 01 2500, Substitution Procedures for products that are not listed.
<b>Q2</b>	Will the cable be required to be OSP rated or simply plenum rated?
<b>A2</b>	OSP rated cable is required in wet & underground locations. All cable inside of the building shall be plenum rated. In exterior or exposed locations, all plenum rated cabling shall be concealed and protected in conduit or raceway.
<b>O3</b>	Will the Genetec License be required to each camera?
<b>A3</b>	Yes

**\*\*\*END OF ADDENDUM\*\*\***